

19

**TAMILNADU FIRE AND RESCUE SERVICES DEPARTMENT  
NO OBJECTION CERTIFICATE**

UNDER SECTION 13 OF THE TAMILNADU FIRE SERVICE ACTS 1985 AND WITH TAMIL NADU FIRE SERVICE RULES  
1990 APPENDIX III

L.Dis.No.6801/A2/2019  
Date: .09 .2019

Office of the District Officer,  
Fire and Rescue Service Department,  
Cuddalore District, Cuddalore - 1

Sub : No Objection Certificate - Annamalai University - Faculty of  
Education - Building - Regarding.

Ref : Your application Letter, Dated:29.07.2019

\*\*\*\*\*


No Objection Certificate is here by granted to run the Educational Building  
Annamalai University (Ground + 2 Floors) in the name of "**Faculty of Education**"  
Survey No.89/2A, 2B, 2C & 3(part) and 76/1,2 Annamalainagar, Chidambaram Taluk,  
Cuddalore District, Subject to the following conditions. This Building is classified as  
Group B Educational Buildings Sub Division **B2** The above premises was  
inspected by N.Rengabazhyam, Station Officer, Chidambaram on 05.08.2019.

Conditions :

1. Fire Extinguishers should be installed as per IS 2190:2010.
2. Hose reel system should be provided for every 1,000 sq.meters
3. An Over Head Tank Having capacity of 10,000 Lit should be provided exclusive  
for Fire Fighting.
4. A Fire pump having capacity of 900 LMP should be provided
5. Trained Fire Personal should be available to operate the system in case of any  
emergency
6. House keeping should be neat and clean.
7. All the Extinguishers have to be recharged and maintained periodically as per  
code practice in 2190:2010
8. Necessary NOC / License has to be obtained from various competent authorities.

(Office Seal with Date)



  
 District Officer  
 Fire and Rescue Services Department  
 Cuddalore District  
 Cuddalore

To - The Dean (Annamalai University)  
 M/s Faculty of Education  
 Annamalai Nagar, Chidambaram Taluk  
 Cuddalore District

